

# **Dunamenti G3 Repowering: MINIMIZING INVESTMENT COST**

through conversion of a 220 MW thermal power  
plant into a 400 MW CCGT

PowerGen Europe, June 13<sup>th</sup> 2012

Rob Versteirt - Guillaume Lassaux

# CONTENT

- Project Overview & Goals
- Project Key Success Factors
- Project Achievements

# Dunamenti Power Plant



Százhalombatta

2 gas turbine co-generation units

6 gas/oil fired boilers





Gas/oil fired boiler  
221 MW

## Project Goals:

- Increase efficiency
- Keep investment cost to a minimum

400 MW combined  
cycle power plant

# From Pre-feasibility to Commercial Operation



# CONTENT


- Project Overview & Goals
- **Project Key Success Factors**
- Project Achievements

# CONTENT

- Project Overview & Goals
- **Project Key Success Factors**
  - **Tailored Project Layout**
  - Optimised Balance of Re-use of Equipment vs. Cycle Efficiency
  - Adapted Project Procurement & Implementation
- Project Achievements




# Project Location – Original Layout





# Customize Layout for Defined Location

## Minimize Demolition




Only workshop to be demolished

Re-used steam turbine & electrical buildings



# Customize Layout for Defined Location

Constraint: Infrastructure to be preserved



- Layout of existing roads on the site of the power plant
- Main cable gallery crossing the selected area and supplying power to power plant auxiliaries
- Steam pipe rack to the south of the chosen project location

# Tailored Project Layout



Demolished workshop

Re-used steam turbine & electrical buildings


# CONTENT

- Project Overview & Goals
- Project Key Success Factors
  - Tailored Project Layout
  - Optimised Balance of Re-use of Equipment vs. Cycle Efficiency
  - Adapted Project Procurement & Implementation
- Project Achievements

# Optimised Balance of Re-use of Equipment vs. Cycle Efficiency

- Heat and mass balance comparisons during pre-feasibility phase:
    - Gas turbine: F-class (275-285 MW)
    - Steam turbine: existing or new
    - With existing ST: 2 or 3 pressure levels HRSG
  - Use of existing steam turbine in the combined cycle :
    - HP module: oversized → lower efficiency
    - LP module: expected flow rate matched initial design flow rate
    - Existing HP module offered limited residual lifetime
- ➔ Optimization: replacement of HP turbine with re-use of IP and LP module

# Final Process Flow Diagram





Re-used ST with new HP part: **Lower efficiency (0.4%)** than new ST but **lower investment cost**

3 pressure level HRSG versus 2 pressure level: **+0.6% efficiency**

# Implementation of ST Modifications

- All extractions closed
- Additional LP steam injection point in IP1/IP2 cross-over pipes




- Modern steam turbine controller
  - Adapted to new operation modes
  - Thermal stress computer (HP and IP modules)



# Re-use of Existing Equipment and Common Power Plant Systems

- Partial refurbishment of the steam turbine allowed extensive re-use of the old F-unit equipment
  - ST auxiliary equipment (lube oil, jacking oil, gland steam, vacuum ejector systems)
  - Condenser: new stainless steel tubes
  - ST generator: rewinding
  - Main cooling water system: unchanged
- Re-use of the steam turbine offered additional cost cut-down: "Leverage effect"



# CONTENT

- Project Overview & Goals
- **Project Key Success Factors**
  - Tailored Project Layout
  - Optimised Balance of Re-use of Equipment vs. Cycle Efficiency
  - **Adapted Project Procurement & Implementation**
- Project Achievements

## Procurement Adapted to Tailored Design

- Executed in the framework of an EPCM multi-contract approach (Engineering, Procurement, Construction Management)
  - Scope of the contractual packages was defined in function of the market and project requirements
  - Flexibility for further project optimization and savings
- **Main suppliers:**
  - Gas turbine: ANSALDO ENERGIA V94.3 A4
  - Heat recovery steam generator: CMI
  - Steam turbine: Alstom Hungary
  - Electrical works: Fabricom
  - Civil works: Strabag

# Implementation Project Timelines

# Implementation Project Timelines

April 2009

Civil Works





# Implementation Project Timelines

April 2009

September 2009

Civil Works

HRSG  
erection



# Implementation Project Timelines

April 2009

Civil Works



September 2009

HRS  
G erection



April 2010

Gas Turbine  
Arrival





# Implementation Project Timelines

April 2009

Civil Works



September 2009

HRSG erection



April 2010

Gas Turbine Arrival



December 2010

1<sup>st</sup> Firing



June 24<sup>th</sup>, 2011

Performance Test

# CONTENT

- Project Overview & Goals
- Project Key Success Factors
- Project Achievements



Gas/oil fired boiler  
221 MW

## Project Goals:

- Increase efficiency
- Keep investment cost to a minimum

400 MW combined  
cycle power plant



## Key Success Factors:

- Tailored Project Layout
- Optimised Balance of Re-use of Equipment vs. Cycle Efficiency
- Adapted Project Procurement & Implementation



Gas/oil fired boiler  
221 MW

## Project Goals:

- Increase efficiency
- Keep investment cost to a minimum

400 MW combined  
cycle power plant



Dunamenti G3 unit now in operation: Actual performances better than guaranteed

Investment cost maintained at a low level through an optimized integration in the plant

**A repowering offers a significant cost advantage in comparison with a Greenfield solution**

# Questions?